

TERMS AND CONDITIONS

Name of work:- *Ruv. Levers to be herb. Bokala G.P. Bokala In Tehsil. Kemorave*

1. Conditional and telegraphic tenders are liable to be rejected.
2. All pages of the tender form must be signed before submitting the tender failing which the tender is liable to be treated as invalid.
3. The work shall be executed as per IPH/PWD specification, relevant IS codes and CPHEEO Manual to the entire satisfaction of the Engineer-in-charge.
4. The security, Income tax, sale tax and surcharge and labour welfare cess if any shall be deducted from each running bill of the contractor/firm as applicable.
5. All necessary documents such as income taxes clearance certificate, renewal of registration, CST/GST number shall have to be produced by the contractor/firm before purchase of tender documents.
6. The rates of all the items should be inclusive of all taxes, duties, levies, carriage of material within all leads and lifts etc. to site of work.
7. Manufacturing allowance/ tolerance permitted in, pipe wall thickness shall in no case be more than + 3% of specified thickness in the BIScode However , payment for supplied pipe within permitted variation in thickness on negative side shall be made on pro-rata difference of weight derived on through rate, but for positive side nothing extra payment shall be made.
8. The bends of required degree duly flanged shall be provided by the contractor/firm whenever required as per direction of the Engineer-in-charge. The bends manufactured from parent tubes taking care that nominal bore is not reduced else it will be rejected and shall be 100% test checked by Assistant Engineer before burring.
9. The tenderers should ascertain the availability of MSERW/API pipe as per schedule of quantity before quoting their rates.
10. Test certificate, inspection and specification.
 - (a) The tenderer shall have to produce manufacturers test certificate for all appertanances.
 - (b) 3rd party inspection shall be got done from one of the following.
 1. Rites, 2. Detnorsake Varitas 3. Burpau, Varitas 4. SGS 5. M/S Quality Service & Solutiuon. New Delhi-48.
 - (c) Payment only for the accepted and fully tested work shall be released.
 - (d) The pipes shall be measured and weighted in the presence of authorized representative of the department at site/weight bridge. The documents showing the laden and unladen weights and lengths shall be submitted to Engineer-in-Charge alongwith post delivery bill.
11. Any damages caused to any public/private property during the course of execution of work shall be restored by the contractor and if, not done within a reasonable time then the same shall be restored by the department at contractor's cost.
12. L-section and plan of pipe line can be seen in the Divisional office on any working day. However contractor shall visit the site and work out filed detail for laying of pipe lines as per site conditions and should quote his rates accordingly.